



California State Fire Marshal Information Bulletin 14-009

October 16, 2014

Siemens Recalls Audible Fire Alarm Base Due to Risk of Injury

Siemens in conjunction with the U.S. Consumer Product Safety Commission (CPSC) announced a recall of Model SBGA-34 Audible Fire Alarm Base. Consumers should stop using this product unless otherwise instructed. It is illegal to resell or attempt to resell a recalled consumer product.

Recall Summary

Name of Product: SBGA-34 Audible Fire Alarm Base

Hazard: The fire alarm base can fail to sound an alarm, posing a risk of personal injury and property damage.

Remedy: Replace

Consumer Contact: Siemens at (800) 516-9964 from 7 a.m. to 5:30 p.m. CT Monday through Friday, or online at www.usa.siemens.com/buildingtechnologies and click on "Product Safety Recall" for more information.

Recall Details

Units: About 9,000

Description: This recall involves the SBGA-34 audible base that is affixed to ceiling-mounted smoke detectors in order to sound an alarm when the fire alarm system is activated. The audible base has part number S54370-F13 and date codes 0113 through 2314 in a WWYY format printed on a white label on the back of the unit part affixed to the wall. "MODEL SBGA-34" is printed on a blue label also affixed to the back of the device.

For a full list of fire detectors and alarm systems that use these recalled bases, click here:

<http://www.cpsc.gov/en/Recalls/2014/Siemens-Recalls-Audible-Fire-Alarm-Base/>

Incidents/Injuries: None reported.

Remedy: Consumers should immediately contact Siemens to schedule a free inspection and replacement of the recalled audible base. Siemens is directly contacting known owners.



California State Fire Marshal Information Bulletin 14-009

Sold at: Siemens sales offices, authorized distributors and installers nationwide from February 2013 through June 2014 for about \$120.

Importer: Siemens, of Buffalo, Illinois.

Manufacturer: Beijing Siemens Cerberus Electronics Ltd., of China

Manufactured in: China

Consumer Contact: Contact Siemens at (800) 516-9964 from 7 a.m. to 5:30 p.m. (Central Time) Monday through Friday, or online at www.usa.siemens.com/buildingtechnologies

To report a dangerous product or a product-related injury go online to www.SaferProducts.gov or call CPSC's Hotline at (800) 638-2772 or teletypewriter at (301) 595-7054 for the hearing impaired.

CAUTION
INSULATE ALL CABLE DRAIN
WIRES from any conduit
or other earth grounded
electrical box.

E=Test Station
E0114 01=Week
14=Year

SIEMENS MODEL 58CA-34
INSTALLATION INSTRUCTIONS: ANY VENDOR'S
WALL CURRENT SHALL BE 24 VOLTS
SIGNALING 500 MA 24 VDC
500 MA 24 VDC 200/240 VAC
UL LISTED
ULC LISTED
APPROXIMATE 1

